



**ALBUQUERQUE  
PUBLIC SCHOOLS**

*Accelerate Progress for Students*

Rennette R. Apodaca, MPA, CPPO  
EXECUTIVE DIRECTOR OF PROCUREMENT

Raquel Reedy  
SUPERINTENDENT

**RFP NO. 19-042RR  
ADDENDUM #2**

February 4, 2019

Please see following questions and answers regarding RFP:

**Question:**

Will the patch panels being installed be additional, or will they be replacing existing patch panels? If they are replacing existing, will vendor be responsible for exterminating and testing the existing cable that will be removed?

**Answer:**

Vendors will be using existing patch panel ports. It is expected that the selected vendor will be able to use patch panel ports that are vacated due to the WAP move to Center of the Room. The existing Cat5 that runs from the old location will have to be removed from the existing patch panel and labeled, as they will be abandoned in place. If there is an instance, where a new patch panel is needed; APS will provide.

**ACKNOWLEDGE ADDENDUM WITH RFP:**

**Addenda not signed and returned may consider the RFP non-responsive and may be rejected.**

---

**COMPANY/FIRM NAME**

---

**SIGNATURE**

---

**DATE**

---

**Robert Russell, Interim Director**