

February 28th, 2020

# ADDENDUM NO. 3

TO ALL PLAN HOLDERS FOR:

## APS Ernie Pyle Middle School Reroofing & HVAC Upgrades Project

#RFP No. #20-034RRR

APS Project No. 0450.5630.31713

GTH Project No. 1910

**Notice to Proposers:** The following additions, deletions, revisions, approvals and clarifications shall be incorporated into the Contract Documents of the above project. All other provisions of the Contract Documents shall remain unchanged.

This addendum is hereby made a part of the Contract Documents to the same extent as those provisions contained in the original documents. Each Proposer shall acknowledge receipt of this addendum on the Bid Proposal Form in the space provided.

This addendum contains 3 ea. 8.5" x 11" pages.  
1 ea. 42" x 36" pages.

**Alan A. Robertson**

2-28-20

Gregory T. Hicks, Registered Architect

Date

**GREGORY T. HICKS & ASSOCIATES, P.C.**

110 2<sup>nd</sup> St. SW Suite 204 Albuquerque, NM 87102

## **Clarifications & General Information:**

---

1. Fire Alarm system work shall be provided by APS' on call contractor Sound and Signal but shall be included in the Contractor's scope of work and pricing. All other low-voltage work will be direct from APS' on call contractor Sound and Signal to APS.

2. Please replace the existing paragraph on Sheet G101 under Special Systems Work by the Owners Separate Contractor. Replace:

“1. THIS SECTION APPLIES TO ALL LOW-VOLTAGE SPECIAL SYSTEMS WORK INCLUDING: FIRE ALARMS, SECURITY SYSTEMS, CCTV, INTERCOM (INCLUDING SCHOOL BELLS), VOICE/DATA, SATELLITE ANTENNAS, AND IRRIGATION ANTENNAS.”

With the paragraph:

“1. THIS SECTION APPLIES TO ALL LOW-VOLTAGE SPECIAL SYSTEMS WORK INCLUDING: SECURITY SYSTEMS, CCTV, INTERCOM (INCLUDING SCHOOL BELLS), VOICE/DATA, SATELLITE ANTENNAS, AND IRRIGATION ANTENNAS.

## **Prior Approvals:**

---

<b>Section/Item</b>	<b>Manufacturer</b>	<b>Remarks</b>
No Prior Approvals have been requested, issued or approved.		

## **Specifications:**

---

No Changes at this time.

## **Drawings:**

---

No Changes at this time.

## **Mechanical Addendum:**

---

February 28, 2020

Mechanical Addendum #2

Sheet M-601

1. Coil Piping Package Valve Schedule

Piping packages to come with flow control devices or circuit setter for associated flow.

Sheet M-501

1. Coil details
  - a. No existing circuit setters exist or are to be reused.

APS Ernie Pyle Middle School Reroofing and HVAC Replacement. Addendum No. 2

## **Electrical Addendum:**

---

Question:

“Please provide the location of panel PB as this information is not shown on the drawings and will be necessary to provide the wire and conduit lengths?”

Response:

Please find attached updated 42”x36” Version of E-113 showing the location of panel PB.

**END OF ADDENDUM**

